



## ARIZONA DEPARTMENT OF ENVIRONMENTAL QUALITY AIR QUALITY CLASS II MINOR SOURCE PERMIT

**COMPANY:** *General Motors Corporation*  
**FACILITY:** *General Motors Desert Proving Ground - Yuma*  
**PERMIT #:** *47943*  
**DATE ISSUED:** *Draft*  
**EXPIRY DATE:**

---

### SUMMARY

This Class II Operating Permit is issued to General Motors Corporation for operation of its new motor vehicle proving grounds facility near Yuma, Arizona. The facility is operated for the purpose of conducting vehicle-testing programs for research and development.

This permit is for operation of various propane-fired units (water heaters, heating ventilation air conditioning (HVAC) units, etc.), a diesel-fired internal combustion engine for an emergency fire water pump, and a spark-ignition propane-fired internal combustion engine for emergency power generation. There is a Gasoline Dispensing Facility with Above-ground Storage Tanks (ASTs) and Underground Storage Tanks (USTs) covered by this permit as well.

The equipment covered by this permit can be found in Attachment "C".

This permit is issued in accordance with Arizona Revised Statute (A.R.S.) §49-426. It contains requirements from Title 18, Chapter 2 of the Arizona Administrative Code (A.A.C.).

## TABLE OF CONTENTS

ATTACHMENT “A”: GENERAL PROVISIONS .....	3
I. PERMIT EXPIRATION AND RENEWAL.....	3
II. COMPLIANCE WITH PERMIT CONDITIONS .....	3
III. PERMIT REVISION, REOPENING, REVOCATION AND REISSUANCE, OR TERMINATION FOR CAUSE .....	3
IV. POSTING OF PERMIT .....	4
V. FEE PAYMENT .....	4
VI. ANNUAL EMISSION INVENTORY QUESTIONNAIRE .....	4
VII. COMPLIANCE CERTIFICATION .....	4
VIII. CERTIFICATION OF TRUTH, ACCURACY AND COMPLETENESS .....	4
IX. INSPECTION AND ENTRY .....	5
X. PERMIT REVISION PURSUANT TO FEDERAL HAZARDOUS AIR POLLUTANT STANDARD .....	5
XI. ACCIDENTAL RELEASE PROGRAM.....	5
XII. EXCESS EMISSIONS, PERMIT DEVIATIONS, AND EMERGENCY REPORTING..	6
XIII. RECORD KEEPING REQUIREMENTS .....	10
XIV. REPORTING REQUIREMENTS .....	11
XV. DUTY TO PROVIDE INFORMATION.....	11
XVI. PERMIT AMENDMENT OR REVISION.....	11
XVII. FACILITY CHANGE WITHOUT A PERMIT REVISION.....	11
XVIII. TESTING REQUIREMENTS .....	14
XIX. PROPERTY RIGHTS.....	15
XX. SEVERABILITY CLAUSE .....	15
XXI. PERMIT SHIELD.....	15
ATTACHMENT “B”: SPECIFIC CONDITIONS .....	17
I. RELATIONSHIP OF PERMIT TO APPLICABLE STATE IMPLEMENTATION PLAN .....	17
ATTACHMENT “C”: EQUIPMENT LIST .....	35

**ATTACHMENT "A": GENERAL PROVISIONS**  
**Air Quality Control Permit No. 47943**  
**For**  
**General Motors Desert Proving Ground - Yuma**

**I. PERMIT EXPIRATION AND RENEWAL**

[ARS § 49-426.F, A.A.C. R18-2-304.C.2, and -306.A.1]

- A.** This permit is valid for a period of five years from the date of issuance.
- B.** The Permittee shall submit an application for renewal of this permit at least 6 months, but not more than 18 months, prior to the date of permit expiration.

**II. COMPLIANCE WITH PERMIT CONDITIONS**

[A.A.C. R18-2-306.A.8.a and b]

- A.** The Permittee shall comply with all conditions of this permit including all applicable requirements of the Arizona air quality statutes and air quality rules. Any permit noncompliance constitutes a violation of the Arizona Revised Statutes and is grounds for enforcement action; for permit termination, revocation and reissuance, or revision; or for denial of a permit renewal application. In addition, noncompliance with any federally enforceable requirement constitutes a violation of the Clean Air Act.
- B.** It shall not be a defense for a Permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.

**III. PERMIT REVISION, REOPENING, REVOCATION AND REISSUANCE, OR TERMINATION FOR CAUSE**

[A.A.C. R18-2-306.A.8.c, -321.A.1.c-d, and -321.A.2]

- A.** The permit may be revised, reopened, revoked and reissued, or terminated for cause. The filing of a request by the Permittee for a permit revision, revocation and reissuance, termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition.
- B.** The permit shall be reopened and revised under any of the following circumstances
  - 1.** The Director or the Administrator determines that the permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of the permit.
  - 2.** The Director or the Administrator determines that the permit needs to be revised or revoked to assure compliance with the applicable requirements.
- C.** Proceedings to reopen and reissue a permit, including appeal of any final action relating to a permit reopening, shall follow the same procedures as apply to initial permit issuance and shall affect only those parts of the permit for which cause to reopen exists. Such reopenings shall be made as expeditiously as practicable. Permit reopenings shall not result in a resetting of the five-year permit term.

#### **IV. POSTING OF PERMIT**

[A.A.C. R18-2-315]

- A.** The Permittee shall post this permit or a certificate of permit issuance where the facility is located in such a manner as to be clearly visible and accessible. All equipment covered by this permit shall be clearly marked with one of the following:
1. Current permit number; or
  2. Serial number or other equipment ID number that is also listed in the permit to identify that piece of equipment.
- B.** A copy of the complete permit shall be kept on site.

#### **V. FEE PAYMENT**

[A.A.C. R18-2-306.A.9 and -326]

The Permittee shall pay fees to the Director pursuant to ARS § 49-426(E) and A.A.C. R18-2-326.

#### **VI. ANNUAL EMISSION INVENTORY QUESTIONNAIRE**

[A.A.C. R18-2-327.A and B]

- A.** The Permittee shall complete and submit to the Director an annual emissions inventory questionnaire. The questionnaire is due by March 31<sup>st</sup> or ninety days after the Director makes the inventory form available each year, whichever occurs later, and shall include emission information for the previous calendar year.
- B.** The questionnaire shall be on a form provided by the Director and shall include the information required by A.A.C. R18-2-327.

#### **VII. COMPLIANCE CERTIFICATION**

[A.A.C. R18-2-309.2.a, -309.2.c-d, and -309.5.d]

- A.** The Permittee shall submit a compliance certification to the Director annually which describes the compliance status of the source with respect to each permit condition. The certification shall be submitted no later than March 31<sup>st</sup>, and shall report the compliance status of the source during the period between January 1<sup>st</sup> and December 31<sup>st</sup> of the previous year.

The compliance certifications shall include the following:

1. Identification of each term or condition of the permit that is the basis of the certification;
2. The Identification of the methods or other means used by the owner or operator for determining the compliance status with each term and condition during the certification period;
3. The status of compliance with the terms and conditions of the permit for the period covered by the certification, including whether compliance during the period was continuous or intermittent. The certification shall be based on the methods or means designated in Condition VII.A.2 above. The certifications shall identify each deviation and take it into account for consideration in the compliance certification;

4. All instances of deviations from permit requirements reported pursuant to Condition XII.B of this Attachment; and
  5. Other facts the Director may require in determining the compliance status of the source.
- B.** A progress report on all outstanding compliance schedules shall be submitted every six months beginning with six months after permit issuance.

## **VIII. CERTIFICATION OF TRUTH, ACCURACY AND COMPLETENESS**

[A.A.C. R18-2-304.H]

Any document required to be submitted by this permit, including reports, shall contain a certification by a responsible official of truth, accuracy, and completeness. This certification shall state that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

## **IX. INSPECTION AND ENTRY**

[A.A.C. R18-2-309.4]

Upon presentation of proper credentials, the Permittee shall allow the Director or the authorized representative of the Director to:

- A.** Enter upon the Permittee's premises where a source is located, emissions-related activity is conducted, or where records are required to be kept under the conditions of the permit;
- B.** Have access to and copy, at reasonable times, any records that are required to be kept under the conditions of the permit;
- C.** Inspect, at reasonable times, any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under the permit;
- D.** Sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or other applicable requirements; and
- E.** Record any inspection by use of written, electronic, magnetic, and photographic media.

## **X. PERMIT REVISION PURSUANT TO FEDERAL HAZARDOUS AIR POLLUTANT STANDARD**

[A.A.C. R18-2-304.C]

If this source becomes subject to a standard promulgated by the Administrator pursuant to Section 112(d) of the Act, then the Permittee shall, within twelve months of the date on which the standard is promulgated, submit an application for a permit revision demonstrating how the source will comply with the standard

## **XI. ACCIDENTAL RELEASE PROGRAM**

[40 CFR Part 68]

If this source becomes subject to the provisions of 40 CFR Part 68, then the Permittee shall comply with these provisions according to the time line specified in 40 CFR Part 68.

## **XII. EXCESS EMISSIONS, PERMIT DEVIATIONS, AND EMERGENCY REPORTING**

### **A. Excess Emissions Reporting**

[A.A.C. R18-2-310.01.A and -310.01.B]

#### **1. Excess emissions shall be reported as follows:**

- a. The Permittee shall report to the Director any emissions in excess of the limits established by this permit. Such report shall be in two parts as specified below:
  - (1) Notification by telephone or facsimile within 24 hours of the time when the Permittee first learned of the occurrence of excess emissions including all available information from Condition XII.A.1.b below.
  - (2) Detailed written notification by submission of an excess emissions report within 72 hours of the notification pursuant to Condition XII.A.1.a.(1) above.
- b. The report shall contain the following information:
  - (1) Identity of each stack or other emission point where the excess emissions occurred;
  - (2) Magnitude of the excess emissions expressed in the units of the applicable emission limitation and the operating data and calculations used in determining the magnitude of the excess emissions;
  - (3) Date, time and duration, or expected duration, of the excess emissions;
  - (4) Identity of the equipment from which the excess emissions emanated;
  - (5) Nature and cause of such emissions;
  - (6) If the excess emissions were the result of a malfunction, steps taken to remedy the malfunction and the steps taken or planned to prevent the recurrence of such malfunctions; and
  - (7) Steps taken to limit the excess emissions. If the excess emissions resulted from start-up or malfunction, the report shall contain a list of the steps taken to comply with the permit procedures.

2. In the case of continuous or recurring excess emissions, the notification requirements of this section shall be satisfied if the source provides the required notification after excess emissions are first detected and includes in such notification an estimate of the time the excess emissions will continue. Excess emissions occurring after the estimated time period, or changes in the nature of the emissions as originally reported, shall require additional notification pursuant to Condition XII.A.1 above.

[A.A.C. R18-2-310.01.C]

**B. Permit Deviations Reporting**

[A.A.C. R18-2-306.A.5.b]

The Permittee shall promptly report deviations from permit requirements, including those attributable to upset conditions as defined in the permit, the probable cause of such deviations, and any corrective actions or preventive measures taken. Prompt reporting shall mean that the report was submitted to the Director by certified mail, facsimile, or hand delivery within two working days of the time when emission limitations were exceeded due to an emergency or within two working days of the time when the owner or operator first learned of the occurrence of a deviation from a permit requirement.

**C. Emergency Provision**

[A.A.C. R18-2-306.E]

1. An “emergency” means any situation arising from sudden and reasonable unforeseeable events beyond the control of the source, including acts of God, that require immediate corrective action to restore normal operation, and that causes the source to exceed a technology-based emission limitation under the permit, due to unavoidable increases in emissions attributable to the emergency. An emergency shall not include noncompliance to the extent caused by improperly designed equipment, lack of preventative maintenance, careless or improper operation, or operator error.
2. An emergency constitutes an affirmative defense to an action brought for noncompliance with such technology-based emission limitations if Condition XII.C.3 is met.
3. The affirmative defense of emergency shall be demonstrated through properly signed, contemporaneous operating logs, or other relevant evidence that:
  - a. An emergency occurred and that the Permittee can identify the cause(s) of the emergency;
  - b. The permitted facility was being properly operated at the time;
  - c. During the period of the emergency, the Permittee took all reasonable steps to minimize levels of emissions that exceeded the emissions standards or other requirements in the permit; and
  - d. The Permittee submitted notice of the emergency to the Director by certified mail, facsimile, or hand delivery within two working days of the time when emission limitations were exceeded due to the emergency. This notice shall contain a description of the emergency, any steps taken to mitigate emissions, and corrective action taken.
4. In any enforcement proceeding, the Permittee seeking to establish the occurrence of an emergency has the burden of proof.
5. This provision is in addition to any emergency or upset provision contained in any applicable requirement.

**D. Compliance Schedule**

[ARS § 49-426.I.5]

1. For any excess emission or permit deviation that cannot be corrected with 72 hours, the Permittee is required to submit a compliance schedule to the Director within 21 days of such occurrence. The compliance schedule shall include a schedule of remedial measures, including an enforceable sequence of actions with milestones, leading to compliance with the permit terms or conditions that have been violated.

**E. Affirmative Defenses for Excess Emissions Due to Malfunctions, Startup, and Shutdown**

[A.A.C. R18-2-310]

1. Applicability

This rule establishes affirmative defenses for certain emissions in excess of an emission standard or limitation and applies to all emission standards or limitations except for standards or limitations:

- a. Promulgated pursuant to Sections 111 or 112 of the Act;
- b. Promulgated pursuant to Titles IV or VI of the Clean Air Act;
- c. Contained in any Prevention of Significant Deterioration (PSD) or New Source Review (NSR) permit issued by the U.S. EPA;
- d. Contained in A.A.C. R18-2-715.F; or
- e. Included in a permit to meet the requirements of A.A.C. R18-2-406.A.5.

2. Affirmative Defense for Malfunctions

Emissions in excess of an applicable emission limitation due to malfunction shall constitute a violation. When emissions in excess of an applicable emission limitation are due to a malfunction, the Permittee has an affirmative defense to a civil or administrative enforcement proceeding based on that violation, other than a judicial action seeking injunctive relief, if the Permittee has complied with the reporting requirements of A.A.C. R18-2-310.01 and has demonstrated all of the following:

- a. The excess emissions resulted from a sudden and unavoidable breakdown of process equipment or air pollution control equipment beyond the reasonable control of the Permittee;
- b. The air pollution control equipment, process equipment, or processes were at all times maintained and operated in a manner consistent with good practice for minimizing emissions;
- c. If repairs were required, the repairs were made in an expeditious fashion when the applicable emission limitations were being exceeded. Off-shift labor and overtime were utilized where practicable to ensure that the repairs were made as expeditiously as possible. If off-shift labor and overtime were not utilized, the Permittee satisfactorily demonstrated that the measures were impracticable;
- d. The amount and duration of the excess emissions (including any bypass operation) were minimized to the maximum extent practicable during periods of such emissions;



- e. All reasonable steps were taken to minimize the impact of the excess emissions on ambient air quality;
- f. The excess emissions were not part of a recurring pattern indicative of inadequate design, operation, or maintenance;
- g. During the period of excess emissions there were no exceedances of the relevant ambient air quality standards established in Title 18, Chapter 2, Article 2 of the Arizona Administrative Code that could be attributed to the emitting source;
- h. The excess emissions did not stem from any activity or event that could have been foreseen and avoided, or planned, and could not have been avoided by better operations and maintenance practices;
- i. All emissions monitoring systems were kept in operation if at all practicable; and
- j. The Permittee's actions in response to the excess emissions were documented by contemporaneous records

3. Affirmative Defense for Startup and Shutdown

- a. Except as provided in Condition XII.E.3.b below, and unless otherwise provided for in the applicable requirement, emissions in excess of an applicable emission limitation due to startup and shutdown shall constitute a violation. When emissions in excess of an applicable emission limitation are due to startup and shutdown, the Permittee has an affirmative defense to a civil or administrative enforcement proceeding based on that violation, other than a judicial action seeking injunctive relief, if the Permittee has complied with the reporting requirements of A.A.C. R18-2-310.01 and has demonstrated all of the following:
  - (1) The excess emissions could not have been prevented through careful and prudent planning and design;
  - (2) If the excess emissions were the result of a bypass of control equipment, the bypass was unavoidable to prevent loss of life, personal injury, or severe damage to air pollution control equipment, production equipment, or other property;
  - (3) The air pollution control equipment, process equipment, or processes were at all times maintained and operated in a manner consistent with good practice for minimizing emissions;
  - (4) The amount and duration of the excess emissions (including any bypass operation) were minimized to the maximum extent practicable during periods of such emissions;
  - (5) All reasonable steps were taken to minimize the impact of the excess emissions on ambient air quality;
  - (6) During the period of excess emissions there were no exceedances of the relevant ambient air quality standards established in Title 18, Chapter 2, Article 2 of the Arizona

Administrative Code that could be attributed to the emitting source;

- (7) All emissions monitoring systems were kept in operation if at all practicable; and
    - (8) Contemporaneous records documented the Permittee's actions in response to the excess emissions.
  - b. If excess emissions occur due to a malfunction during routine startup and shutdown, then those instances shall be treated as other malfunctions subject to Condition XII.E.2 above.
4. Affirmative Defense for Malfunctions During Scheduled Maintenance
  - a. If excess emissions occur due to a malfunction during scheduled maintenance, then those instances will be treated as other malfunctions subject to Condition XII.E.2 above.
5. Demonstration of Reasonable and Practicable Measures
  - a. For an affirmative defense under Condition XII.E.2 or XII.E.3 above, the Permittee shall demonstrate, through submission of the data and information required by Condition XII.E and A.A.C. R18-2-310.01, that all reasonable and practicable measures within the Permittee's control were implemented to prevent the occurrence of the excess emissions.

### **XIII. RECORD KEEPING REQUIREMENTS**

[A.A.C. R18-2-306.A.4]

- A. The Permittee shall keep records of all required monitoring information including, but not limited to, the following:
  1. The date, place as defined in the permit, and time of sampling or measurements;
  2. The date(s) analyses were performed;
  3. The name of the company or entity that performed the analyses;
  4. A description of the analytical techniques or methods used;
  5. The results of such analyses; and
  6. The operating conditions as existing at the time of sampling or measurement.
- B. The Permittee shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, report, or application. Support information includes all calibration and maintenance records and all original strip-chart recordings or other data recordings for continuous monitoring instrumentation, and copies of all reports required by the permit.
- C. All required records shall be maintained either in an unchangeable electronic format or in a handwritten logbook utilizing indelible ink.

#### **XIV. REPORTING REQUIREMENTS**

[A.A.C. R18-2-306.A.5.a]

The Permittee shall submit the following reports:

- A.** Compliance certifications in accordance with Section VII of Attachment “A”.
- B.** Excess emission; permit deviation, and emergency reports in accordance with Section XII of Attachment “A”.
- C.** Other reports required by any condition of Attachment “B”.

#### **XV. DUTY TO PROVIDE INFORMATION**

[A.A.C. R18-2-304.G and -306.A.8.e]

- A.** The Permittee shall furnish to the Director, within a reasonable time, any information that the Director may request in writing to determine whether cause exists for revising, revoking and reissuing, or terminating the permit, or to determine compliance with the permit. Upon request, the Permittee shall also furnish to the Director copies of records required to be kept by the permit. For information claimed to be confidential, the Permittee shall furnish an additional copy of such records directly to the Administrator along with a claim of confidentiality.
- B.** If the Permittee has failed to submit any relevant facts or has submitted incorrect information in the permit application, the Permittee shall, upon becoming aware of such failure or incorrect submittal, promptly submit such supplementary facts or corrected information.

#### **XVI. PERMIT AMENDMENT OR REVISION**

[A.A.C. R18-2-317.01, -318, -319, and -320]

The Permittee shall apply for a permit amendment or revision for changes to the facility which do not qualify for a facility change without revision under Section XVII, as follows:

- A.** Facility Changes that Require a Permit Revision - Class II (A.A.C. R18-2-317.01);
- B.** Administrative Permit Amendment (A.A.C. R18-2-318);
- C.** Minor Permit Revision (A.A.C. R18-2-319); and
- D.** Significant Permit Revision (A.A.C. R18-2-320)
  - 1.** The applicability and requirements for such action are defined in the above referenced regulations.

#### **XVII. FACILITY CHANGE WITHOUT A PERMIT REVISION**

[A.A.C. R18-2-306.A.4 and -317.02]

- A.** Except for a physical change or change in the method of operation at a Class II source requiring a permit revision under A.A.C. R18-2-317.01, or a change subject to logging or

notice requirements in Conditions XVII.B and XVII.C below, a change at a Class II source shall not be subject to revision, notice, or logging requirements under this Section.

**B.** Except as otherwise provided in the conditions applicable to an emissions cap created under A.A.C. R18-2-306.02, the following changes may be made if the source keeps on site records of the changes according to Appendix 3 of the Arizona Administrative Code:

1. Implementing an alternative operating scenario, including raw materials changes;
2. Changing process equipment, operating procedures, or making any other physical change if the permit requires the change to be logged;
3. Engaging in any new insignificant activity listed in A.A.C. R18-2-101.57.a through A.A.C. R18-2-101.57.i but not listed in the permit;
4. Replacing an item of air pollution control equipment listed in the permit with an identical (same model, different serial number) item. The Director may require verification of efficiency of the new equipment by performance tests; and
5. A change that results in a decrease in actual emissions if the source wants to claim credit for the decrease in determining whether the source has a net emissions increase for any purpose. The logged information shall include a description of the change that will produce the decrease in actual emissions. A decrease that has not been logged is creditable only if the decrease is quantifiable, enforceable, and otherwise qualifies as a creditable decrease.

**C.** Except as provided in the conditions applicable to an emissions cap created under A.A.C. R18-2-306.02, the following changes may be made if the source provides written notice to the Department in advance of the change as provided below:

1. Replacing an item of air pollution control equipment listed in the permit with one that is not identical but that is substantially similar and has the same or better pollutant removal efficiency: 7 days. The Director may require verification of efficiency of the new equipment by performance tests;
2. A physical change or change in the method of operation that increases actual emissions more than 10 percent of the major source threshold for any conventional pollutant but does not require a permit revision: 7 days;
3. Replacing an item of air pollution control equipment listed in the permit with one that is not substantially similar but that has the same or better efficiency: 30 days. The Director may require verification of efficiency of the new equipment by performance tests;
4. A change that would trigger an applicable requirement that already exists in the permit for 30 days unless otherwise required by the applicable requirement;
5. A change that amounts to reconstruction of the source or an affected facility: 7 days. For the purposes of this subsection, reconstruction of a source or an affected facility shall be presumed if the fixed capital cost of the new components exceeds 50 percent of the fixed capital cost of a comparable entirely new source or affected facility and the changes to the components have occurred over the 12 consecutive months beginning with commencement of construction; and

6. A change that will result in the emissions of a new regulated air pollutant above an applicable regulatory threshold but that does not trigger a new applicable requirement for that source category: 30 days. For purposes of this requirement, an applicable regulatory threshold for a conventional air pollutant shall be 10 percent of the applicable major source threshold for that pollutant.
- D.** For each change under Condition XVII.C above, the written notice shall be by certified mail or hand delivery and shall be received by the Director the minimum amount of time in advance of the change. Notifications of changes associated with emergency conditions, such as malfunctions necessitating the replacement of equipment, may be provided with less than required notice, but must be provided as far in advance of the change, or if advance notification is not practicable, as soon after the change as possible. The written notice shall include:
1. When the proposed change will occur;
  2. A description of the change;
  3. Any change in emissions of regulated air pollutants; and
  4. Any permit term or condition that is no longer applicable as a result of the change.
- E.** A source may implement any change in Condition XVII.C above without the required notice by applying for a minor permit revision under A.A.C. R18-2-319 and complying with subsection A.A.C. R18-2-319.D.2 and A.A.C. R18-2-319.G.
- F.** The permit shield described in A.A.C. R18-2-325 shall not apply to any change made under this Section, other than implementation of an alternate operating scenario under Condition XVII.B.1.
- G.** Notwithstanding any other part of this Section, the Director may require a permit to be revised for any change that, when considered together with any other changes submitted by the same source under this Section over the term of the permit, constitutes a change under subsection A.A.C. R18-2-317.01.A.
- H.** If a source change is described under both Conditions XVII.B and XVII.C above, the source shall comply with Condition XVII.C above. If a source change is described under both Condition XVII.C above and A.A.C. R18-2-317.01.B, the source shall comply with A.A.C. R18-2-317.01.B.
- I.** A copy of all logs required under Condition XVII.B shall be filed with the Director within 30 days after each anniversary of the permit issuance date. If no changes were made at the source requiring logging, a statement to that effect shall be filed instead.
- J.** Logging Requirements
- [A.A.C. R18-2-306.A.4]
1. Each log entry required by a change under Condition XVII.B shall include at least the following information:
    - a. A description of the change, including:
      - (1) A description of any process change;

- (2) A description of any equipment change, including both old and new equipment descriptions, model numbers, and serial numbers, or any other unique equipment ID number; and
    - (3) A description of any process material change.
  - b. The date and time that the change occurred.
  - c. The provision of A.A.C. R18-2-317.02.B that authorizes the change to be made with logging.
  - d. The date the entry was made and the first and last name of the person making the entry.
2. Logs shall be kept for 5 years from the date created. Logging shall be performed in indelible ink in a bound log book with sequentially number pages, or in any other form, including electronic format, approved by the Director.

## **XVIII. TESTING REQUIREMENTS**

[A.A.C. R18-2-312]

- A.** The Permittee shall conduct performance tests as specified in the permit and at such other times as may be required by the Director.

**B.** Operational Conditions During Testing

Tests shall be conducted during operation at the maximum possible capacity of each unit under representative operational conditions unless other conditions are required by the applicable test method or in this permit. With prior written approval from the Director, testing may be performed at a lower rate. Operations during periods of start-up, shutdown, and malfunction (as defined in A.A.C. R18-2-101) shall not constitute representative operational conditions unless otherwise specified in the applicable standard.

- C.** Tests shall be conducted and data reduced in accordance with the test methods and procedures contained in the Arizona Testing Manual unless modified by the Director pursuant to A.A.C. R18-2-312.B.

**D.** Test Plan

At least 14 calendar days prior to performing a test, the Permittee shall submit a test plan to the Director in accordance with A.A.C. R18-2-312.B and the Arizona Testing Manual. This test plan must include the following:

- 1. Test duration;
- 2. Test location(s);
- 3. Test method(s); and
- 4. Source operation and other parameters that may affect test results.

**E.** Stack Sampling Facilities

The Permittee shall provide, or cause to be provided, performance testing facilities as follows:

1. Sampling ports adequate for test methods applicable to the facility;
2. Safe sampling platform(s);
3. Safe access to sampling platform(s); and
4. Utilities for sampling and testing equipment.

**F. Interpretation of Final Results**

Each performance test shall consist of three separate runs using the applicable test method. Each run shall be conducted for the time and under the conditions specified in the applicable standard. For the purpose of determining compliance with an applicable standard, the arithmetic mean of the results of the three runs shall apply. In the event that a sample is accidentally lost or conditions occur in which one of the three runs is required to be discontinued because of forced shutdown, failure of an irreplaceable portion of the sample train, extreme meteorological conditions, or other circumstances beyond the Permittee's control, compliance may, upon the Director's approval, be determined using the arithmetic mean of the results of the other two runs. If the Director or the Director's designee is present, tests may only be stopped with the Director's or such designee's approval. If the Director or the Director's designee is not present, tests may only be stopped for good cause. Good cause includes: forced shutdown, failure of an irreplaceable portion of the sample train, extreme meteorological conditions, or other circumstances beyond the Permittee's control. Termination of any test without good cause after the first run is commenced shall constitute a failure of the test. Supporting documentation, which demonstrates good cause, must be submitted.

**G. Report of Final Test Results**

A written report of the results of all performance tests shall be submitted to the Director within 30 days after the test is performed. The report shall be submitted in accordance with the Arizona Testing Manual and A.A.C. R18-2-312.A.

**XIX. PROPERTY RIGHTS**

[A.A.C. R18-2-306.A.8.d]

This permit does not convey any property rights of any sort, or any exclusive privilege.

**XX. SEVERABILITY CLAUSE**

[A.A.C. R18-2-306.A.7]

The provisions of this permit are severable. In the event of a challenge to any portion of this permit, or if any portion of this permit is held invalid, the remaining permit conditions remain valid and in force.

**XXI. PERMIT SHIELD**

[A.A.C. R18-2-325]

Compliance with the conditions of this permit shall be deemed compliance with all applicable requirements identified in the portions of this permit subtitled "Permit Shield". The permit shield shall not apply to any minor revisions pursuant to Condition XVI.C of this Attachment and any facility changes without a permit revision pursuant to Section XVII of this Attachment.

**This page was left blank intentionally.**



## **ATTACHMENT “B”: SPECIFIC CONDITIONS**

### **Air Quality Control Permit No. 47943**

#### **For**

### **General Motors Desert Proving Ground - Yuma**

#### **I. RELATIONSHIP OF PERMIT TO APPLICABLE STATE IMPLEMENTATION PLAN**

This permit is issued pursuant to the provisions of the Arizona Revised Statutes (ARS) and constitutes an Installation Permit for the purpose of the applicable State Implementation Plan.

[ARS § 49-404.c and -426]

#### **II. FACILITY WIDE REQUIREMENTS**

- A.** Within 180 days of issuance, the Permittee shall have on-site or on-call a person who is certified in EPA Reference Method 9 for the observation and evaluation of visible emissions. [A.A.C. R18-2-306.A.3.c]
- B.** At the time the compliance certifications required by Section VII of Attachment “A” are submitted, the Permittee shall submit summary reports of all monitoring and recordkeeping activities required by this attachment. [A.A.C. R18-2-306.A.5.a]
- C.** The Permittee shall maintain on-site records of the manufacturer’s specifications for all equipment. [A.A.C. R18-2-306.A.4]
- D.** Monitoring, Recordkeeping, and Reporting Requirements
  - 1. The Permittee shall maintain logs of all emission-related maintenance activities performed on the emissions units, and make them available to ADEQ upon request. [A.A.C. R18-2-306.A.3.c]
  - 2. All records, analyses, and reports shall be retained for a minimum of five years from the date of generation. The most recent two years of data shall be kept on-site. [A.A.C. R18-2-306.A.4]

#### **III. PROPANE-FIRED HEATERS**

##### **A. Applicability**

This Section is applicable to the HVAC units and water heaters identified in Attachment “C”.

##### **B. Fuel Limitations**

The Permittee shall only fire propane fuel in the HVAC units and water heaters. [A.A.C. R18-2-306.A.2]

##### **C. Particulate Matter and Opacity**

1. Emissions Limitations and Standards

- a. The Permittee shall not cause, allow or permit the emission of particulate matter, caused by combustion of fuel, from any fuel-burning operation into the atmosphere in excess of the amounts calculated by the following equation:

$$E = 1.02 Q^{0.769}$$

Where

E = the maximum allowable particulate emission rate in pounds-mass per hour

Q = the heat input in million Btu per hour

[A.A.C. R18-2-724.C.1]

- b. For purposes of this Section, the heat input shall be the aggregate heat content of all fuels whose products of combustion pass through a stack or other outlet. The total heat input of all fuel-burning units on a plant or premises shall be used for determining the maximum allowable amount of particulate matter which may be emitted.

[A.A.C. R18-2-724.B]

- c. The Permittee shall not cause, allow or permit the opacity of any plume or effluent from the HVAC units and water heaters to exceed 15 percent.

[A.A.C. R18-724.J]

2. Monitoring, Recordkeeping, and Reporting

- a. The Permittee shall keep records of propane fuel supplier certifications. The certification shall contain information regarding the name of fuel supplier and lower heating value of the fuel. These records shall be made available to ADEQ upon request.

[A.A.C. R18-2-306.A.3.c]

- b. The Permittee shall report all 6-minute periods during which the visible emissions exceed 15 percent opacity, as required under Section XII of Attachment "A".

[A.A.C. R18-2-724.J]

4. Permit Shield

Compliance with this Section shall be deemed compliance with A.A.C. R18-2-724.B, A.A.C R18-2-724.C.1, and A.A.C R18-2-724.J.

[A.A.C. R18-2-325]

#### IV. EMERGENCY FIRE WATER PUMP ENGINE

##### A. Applicability

This Section is applicable to the 252 horsepower (hp) emergency fire water pump, ID#: EM WATER as listed in Attachment "C".

##### B. General Requirements

1. General Operating Requirements

- a. The Permittee shall only purchase a 2008 model year or later emergency fire water pump engine. [A.A.C. R18-306.A.2]
- b. The Permittee shall operate and maintain the engine according to the manufacturer's written instructions or procedures developed by the Permittee that are approved by the engine manufacturer. A copy of the instructions or procedures shall be kept onsite and made available to ADEQ upon request. [40 CFR 60.4211(a) and A.A.C. R18-2-306.A.3]
- c. The Permittee shall only change those engine settings that are permitted by the manufacturer. [40 CFR 60.4211(a)]
- d. The Permittee shall meet the requirements of 40 CFR parts 89, 94, or 1068, as they apply. [40 CFR 60.4211(a)]
- e. The Permittee shall operate and maintain the internal combustion engine according to the manufacturer's written instructions or procedures developed by the Permittee that are approved by the engine manufacturer over the entire life of the engine. [40 CFR 60.4206]

## 2. Fuel Requirements

- a. Beginning October 1, 2007, the Permittee, shall use diesel fuel that meets the following requirements of 40 CFR 80.510(a):
  - i. Sulfur content: 500 parts per million (ppm) maximum; and
  - ii. A minimum cetane index of 40 or a maximum aromatic content of 35 volume percent. [40 CFR 60.4207(a)]
- b. Beginning October 1, 2010, the Permittee, shall use diesel fuel that meets the following requirements of 40 CFR 80.510(b):
  - i. Sulfur content: 15 ppm maximum; and
  - ii. A minimum cetane index of 40 or a maximum aromatic content of 35 volume percent. [40 CFR 60.4207(b)]

## 3. Notification and Reporting Requirements

- a. The Permittee shall keep records of the operation of the engine in emergency and non-emergency service that are recorded through the non-resettable hour meter as required in Section IV(B)(6)(a) of this permit. The owner must record the time of operation of the engine and the reason the engine was in operation during that time. [40 CFR 60.4214(b), 60.4211(e) and 60.7(a)(1)]
- b. If the stationary Compression Ignition (CI) internal combustion engine is equipped with a diesel particulate filter, the owner or operator must keep records of any corrective action taken after the backpressure monitor has notified the owner or operator that the high backpressure limit of the engine is approached. [40 CFR 60.4214(c) and 60.7(a)(1)]

4. Monitoring and Recordkeeping Requirements

a. A fire pump engine manufactured prior to 2009 is required to demonstrate compliance according to one of the methods specified below:

- i. Purchasing an engine certified according to 40 CFR Part 89 or 40 CFR Part 94, as applicable, for the same model year and maximum engine power. The engine shall be installed and configured according to the manufacturer's specifications.
- ii. Keeping records of performance test results for each pollutant for a test conducted on a similar engine. The test shall have been conducted using the methods specified in this 40 CFR 60.4212 or 4213, and the methods shall have been followed correctly.
- iii. Keeping records of engine manufacturer data indicating compliance with the standards.
- iv. Keeping records of control device vendor data indicating compliance with the standards.
- v. Conducting an initial performance test to demonstrate compliance with the emission standards according to the requirements specified in 40 CFR 60.4212, as applicable.

[40 CFR 60.4211(b)]

b. The Permittee of a fire pump engine that is manufactured during or after the 2009 model year shall comply by purchasing an engine certified to the emission standards in Conditions IV.C.1, IV.D.1, and IV.E.1, for the same model year and National Fire Protection Association (NFPA) nameplate engine power. The engine shall be installed and configured according to the manufacturer's specifications.

[40 CFR 60.4211(c)]

c. Certification Recordkeeping

The Permittee shall maintain a copy of engine compliance certifications or other documentation demonstrating that each engine complies with the applicable standards in this Permit, and shall make the documentation available to ADEQ upon request.

[A.A.C. R18-2-306.A.4]

5. Testing Requirements

The Permittee shall conduct performance tests as required by the Director, and shall do so according to 40 CFR 60.4212.

[40 CFR 60.4212 and 60.4213 and A.A.C. R18-312(A)]

6. Additional Emergency Engine Requirements

a. *The Permittee shall install a non-resettable hour meter prior to startup of the engine.*

[40 CFR 60.4209(a) and A.A.C. R18-2-331.A.3.c ]

[Material permit conditions are indicated by underline and italics]

b. Emergency internal combustion engines may be operated for the purpose of maintenance checks and readiness testing, provided that the tests are

recommended by Federal, State, or local government, the manufacturer, the vendor, or the insurance company associated with the engine.

[40 CFR 60.4211(e)]

- c. The Permittee shall not operate the emergency engine for the purposes of maintenance checks and readiness testing for more than 100 hours per year unless the Permittee maintains records identifying the Federal, State, or local standards that require maintenance and testing of emergency internal combustion engines beyond 100 hours per year. Copies of such records shall be provided to ADEQ upon request.

[40 CFR 60.4211(e) and A.A.C. R18-2-306.A.4]

- d. The Permittee may petition the Director for approval of additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the Permittee maintains records indicating that Federal, State, or local standards require maintenance and testing of emergency internal combustion engines beyond 100 hours per year.

[40 CFR 60.4211(e)]

- e. The Permittee shall not operate emergency engines except for emergency purposes, maintenance and testing. There is no time limit on the use of the engine in emergency situations.

[40 CFR 60.4211(e)]

- f. The Permittee shall maintain monthly records of engine operation. The records shall include the purpose of operation and the duration of time the engine was operated. The record shall identify whenever the operation of the engine was for emergency purposes.

[40 CFR 60.4211(e) and A.A.C. R18-2-306.A.4]

7. Permit Shield

Compliance with the conditions of this Part shall be deemed compliance with 40 CFR §§ 60.4206, 60.4207(a) and (b), 60.4209(a), 60.4211(a), (b), (c), (d) and (e), 60.4212, 60.4213, and 60.4214(b) and (c).

[A.A.C. R18-2-325]

**C. Particulate Matter**

1. Emissions Limitations and Standards

The Permittee shall not cause or allow to be emitted into the atmosphere, particulate matter emissions in excess of:

- a. 0.40 grams/horsepower-hr (0.54 grams/KW-hr) if the engine is manufactured in or before the 2008 model year.
- b. 0.15 grams/hr-horsepower (0.20 grams/KW-hr) if the engine is manufactured on or after the 2009 model year.

[40 CFR 60.4205(c)]

2. Air Pollution Control Requirements

If an emergency engine is equipped with a diesel particulate filter to comply with the above emission standards in Condition IV.C.1, the Permittee shall install, maintain and operate the particulate filter in accordance with good air pollution control practices for minimizing emissions.

3. Monitoring and Record Keeping Requirements

- a. If an emergency engine is equipped with a diesel particulate filter to comply with the emission standards in Condition IV.C.1, the Permittee shall install a backpressure monitor on the diesel particulate filter that notifies the Permittee when the high backpressure limit of the engine is approached.

[40 CFR 60.4209(b) and A.A.C. R18-2-331.a.3.c]

[Material permit conditions are indicated by underline and italics]

- b. The Permittee shall operate and maintain the control device according to the manufacturer's written instructions or procedures that are developed by the Permittee and approved by the engine manufacturer. A copy of the instructions or procedures shall be kept onsite and made available to ADEQ upon request.

[40 CFR 60.4211(a) and A.A.C. R18-2-306.A.3]

- c. If the internal combustion engine is equipped with a diesel particulate filter, the Permittee shall keep records of any corrective action taken after the backpressure monitor has notified the Permittee that the high backpressure limit of the engine is approached.

[40 CFR 60.4214(c)]

4. Permit Shield

Compliance with the conditions of this Part shall be deemed compliance with 40 CFR 60.4205(c), 60.4209(b), 60.4211(a) and (b), and 60.4214(c).

[A.A.C. R18-2-325]

**D. Nitrogen Oxides**

1. Emissions Limitations and Standards

The Permittee shall not cause or allow to be emitted into the atmosphere, Non-Methane Hydrocarbons and Nitrogen Oxide emissions in excess of:

- a. 7.8 grams/horsepower-hr (10.5 grams/KW-hr) if the engine is manufactured in or before the 2008 model year.
- b. 3.0 grams/horsepower-hr (4.0 grams/KW-hr) if the engine is manufactured on or after the 2009 model year.

[40 CFR 60.4205(c)]

2. Permit Shield

Compliance with the conditions of this Part shall be deemed compliance with 40 CFR 60.4205(c).

[A.A.C. R18-2-325]

**E. Carbon Monoxide**

1. Emissions Limitations and Standards

The Permittee shall not cause or allow to be emitted into the atmosphere, carbon monoxide emissions in excess of:

- a. 2.6 grams/horsepower-hr (3.5 grams/KW-hr) if the engine is manufactured on or after the 2008 model year.

[40 CFR 60.4205(c)]

2. Permit Shield

Compliance with the conditions of this Part shall be deemed compliance with 40 CFR 60.4205(c). [A.A.C. R18-2-325]

**V. EMERGENCY POWER GENERATOR ENGINE**

**A. Applicability**

The Section is applicable to the 168 hp propane-fired spark-ignition emergency generator, EM GEN as listed in Attachment “C”.

**B. Fuel Use**

The Permittee shall use only propane fuel in the above listed generator.

[A.A.C. R18-2-306.A.2]

**C. Particulate Matter and Opacity**

1. Emission Limitations and Standards

- a. The Permittee shall not cause or allow to be discharged into the atmosphere from the generator stack(s) particulate matter in excess of the amount calculated by the following equation:

$$E = 1.02 Q^{0.769} \text{ where:}$$

E = the maximum allowable particulate emissions rate in pounds-mass per hour

Q = the heat input in million Btu per hour

- b. For the purposes of the calculations required in Condition V.C.1.a. above, the heat input shall be the aggregate heat content of all fuels whose products of combustion pass through a stack or other outlet. The total heat input of all operating fuel-burning units at a plant or premises shall be used for determining the maximum allowable amount of particulate matter which may be emitted.

[A.A.C. R18-2-719.B, and 719.C.1]

c. Opacity

- i. The Permittee shall not cause, allow or permit to be emitted into the atmosphere from any stationary rotating machinery, smoke for any period greater than 10 consecutive seconds which exceeds 40 percent opacity.
- ii. Visible emissions when starting cold equipment shall be exempt from this requirement for the first 10 minutes.

[A.A.C. R18-2-719.E]

2. Monitoring and Recordkeeping

- a. The Permittee shall maintain records of the dates on which any of the activities listed in Conditions V.C.1 above were performed and any

control measures that were taken.

[A.A.C. R18-2-306.A.3.c]

### 3. Opacity Monitoring Requirements

- a. A certified Method 9 observer shall conduct a quarterly survey of visible emissions from the generator when the engine is in operation. The Permittee shall keep a record of the name of the observer, the date and location on which the observation was made, and the results of the observation.
- b. If the observer sees a visible emission from the generator that on an instantaneous basis appears to exceed applicable opacity standard, then the observer shall, if practicable, take a six-minute Method 9 observation of the visible emission.
  - i. If the six-minute opacity of the visible emission is less than or equal to applicable opacity standard, the observer shall make a record of the following:
    - (a) Location, date, and time of the observation; and
    - (b) The result of the Method 9 observation.
  - ii. If the six-minute opacity of the visible emission exceeds applicable opacity standard, then the Permittee shall do the following:
    - (a) Adjust or repair the controls or equipment to reduce opacity to below the applicable standard; and
    - (b) Report it as an excess emission under Section XII.A of Attachment "A".
- c. The Permittee shall keep records of propane fuel supplier certifications. The certification shall contain information regarding the name of fuel supplier and lower heating value of the fuel. These records shall be made available to ADEQ upon request.
- d. The Permittee shall record daily the sulfur content and lower heating value of the fuel being fired in the machine.

[A.A.C. R18-2-306.A.3.c]

[A.A.C. R18-2-306.A.3.c.]

[A.A.C. R18-2-719.I]

### 3. Permit Shield

Compliance with this Part shall be deemed compliance with A.A.C. R18-2-719.B, 719.C.1, 719.E and 719.I.

[A.A.C. R18-2-325]

## VI. GASOLINE DISPENSING FACILITY

### A. Applicability



1. This Section applies to Gasoline Dispensing Facility (GDF) which includes, but is not limited to, the Storage Tanks listed in Attachment "C" of this permit.
2. *The Permittee shall limit the monthly gasoline throughput to no more than 100,000 gallons per month.*

[A.A.C. R18-2-306.01 and A.A.C. R18-2-331.A.3.a]  
[Material permit conditions are indicated by underline and italics]

## **B. Operational Requirements**

1. The Permittee shall not allow gasoline to be handled in a manner that would result in vapor releases to the atmosphere for extended periods of time. Measures to be taken include, but are not limited to, the following:
  - a. Minimize gasoline spills;
  - b. Clean up spills as expeditiously as practicable;
  - c. Cover all open gasoline containers and all gasoline storage tank fill-pipes with a cover having a gasketed seal when not in use;
  - d. Minimize gasoline sent to open waste collection systems that collect and transport gasoline to reclamation and recycling devices, such as oil/water separators.

[40 CFR 63.11117(a) and 63.11116(a)]
2. Except for storage tanks with a capacity of less than 250 gallons, the Permittee shall only load gasoline into storage tanks by utilizing submerged filling and the submerged fill pipes must be no more than 6 inches from the bottom of the storage tank.

[40 CFR 63.11117(b) and (c) A.A.C. R18-2-710. B]
3. The Permittee shall have records available within 24 hours of a request by the Director to document the gasoline throughput.

[40 CFR 63.11117(d)]
4. All pumps and compressors that handle gasoline shall be equipped with mechanical seals or other equipment of equal efficiency to prevent release of organic contaminants into the atmosphere.

[A.A.C. R18-2-710.D]
5. Permit Shield  
Compliance with the conditions this part shall be deemed compliance with 40 CFR 63.11111(c), 63.11132 , 40 CFR 63.11113(a)2, 40 CFR 63.11117(a), 40 CFR 63.11117(b) and (c), 40 CFR 63.11117(d) and 40 CFR 63.11117(e) and A.A.C. R18-2-710.D.

[A.A.C. R18-2-325]

## **C. Notifications**

1. The Permittee shall submit an Initial Notification that the facility is subject to this subpart upon startup of the GDF.

[40 CFR §63.11124(a)]
2. The Initial Notification must contain the information specified below:
  - a. The name and address of the owner and the operator.
  - b. The address (i.e., physical location) of the GDF.

c. A statement that the notification is being submitted in response to 40 CFR 63 Subpart CCCCCC and identifying the gasoline tanks greater than 250 gallons and that submerged fill pipes are no more than 6 inches from the bottom of the tanks.

d. The notification must be submitted to the applicable EPA Regional Office and ADEQ as specified in 40 CFR §63.13.

[40 CFR 63.11124(a)(1)]

3. The Permittee must submit a Notification of Compliance Status which shall be signed by a responsible official who shall certify its accuracy and must indicate whether the source has complied with the requirements of this Section VI of this permit.

[40 CFR 63.11124(a)(2)]

4. If the Permittee is in compliance with the requirements of this Section at the time the Initial Notification required under Section VI.C.2 above the Notification of Compliance Status may be submitted in lieu of the Initial Notification provided it contains the information required under Section VI.C.2.

[40 CFR 63.11124(a)(2)]

5. Permit Shield

Compliance with the conditions of this Part shall be deemed compliance with 40 CFR §63.11124.

[A.A.C. R18-2-325]

#### **D. Testing and Monitoring Requirements**

1. The Permittee shall for each of the gasoline storage tanks, maintain a file of the typical Reid vapor pressure of gasoline stored and of dates of storage. Dates on which the storage vessel is empty shall also be shown.

[A.A.C. R18-2-710.E.1]

2. The Permittee shall record the average monthly temperature and true vapor pressure of gasoline at such temperature if the true vapor pressure is greater than 470 mm Hg (9.1 psia) and the gasoline is stored in a storage vessel other than one equipped with a vapor recovery system or its equivalent.

[A.A.C. R18-2-710.E.2.b]

3. The average monthly storage temperature shall be an arithmetic average calculated for each calendar month, or portion thereof, if storage is for less than a month, from bulk liquid storage temperatures determined at least once every seven days.

[A.A.C. R18-2-710.E.3]

4. The true vapor pressure shall be determined by the procedures in American Petroleum Institute Bulletin 2517, amended as of February 1980 (and no future editions), which is incorporated herein by reference and on file with the Office of the Secretary of State. This procedure is dependent upon determination of the storage temperature and the Reid vapor pressure, which requires sampling of the petroleum liquids in the storage vessels. Unless the Director requires in specific cases that the stored petroleum liquid be sampled, the true vapor pressure may be determined by using the average monthly storage temperature and the typical Reid vapor pressure. For those liquids for which certified specifications limiting the Reid vapor pressure exist, the Reid vapor pressure may be used. For other liquids, supporting analytical data must be made available upon request to the

Director when typical Reid vapor pressure is used.

[A.A.C. R18-2-710.E.4]

5. Permit Shield

Compliance with the conditions of this Part shall be deemed compliance with A.A.C. R18-2-710.B, D, E.1, E.2.b, and E.4

[A.A.C. R18-2-325]

## VII. PARTS WASHERS

### A. Applicability

This Section applies to parts washers listed in Attachment “C” of this permit.

### B. Opacity

1. Emission Limitation

The opacity of any plume or effluent from parts washers shall not be greater than 20 percent.

[A.A.C. R18-2-702.B]

2. Permit Shield

Compliance with the conditions of this part shall be deemed compliance with A.A.C. R18-2-702.B.

[A.A.C. R18-2-325]

### C. Volatile Organic Compounds

1. Emission Limitation

a. The Permittee shall not emit gaseous or odorous materials from equipment, operations, or premises under the Permittee’s control in such quantities or concentrations as to cause air pollution.

[A.A.C. R18-2-730.D]

b. Materials including solvents or other volatile compounds, paints, acids, alkalies, pesticides, fertilizers and manure shall be processed, stored, used, and transported in such a manner and by means that they will not evaporate, leak, escape or be otherwise discharged into the ambient air so as to cause or contribute to air pollution. Where means are available to reduce effectively the contribution to air pollution from evaporation, leakage or discharge, the installation and use of such control methods, devices, or equipment shall be mandatory.

[A.A.C. R18-2-730.F]

c. Where a stack, vent or other outlet is at such a level that fumes, gas mist, odor, smoke, vapor or any combination thereof constituting air pollution is discharged to adjoining property, the Director may require the installation of abatement equipment or the alteration of such stack, vent, or other outlet by the owner or operator thereof to a degree that will adequately dilute, reduce or eliminate the discharge of air pollution to adjoining property.

[A.A.C. R18-2-730.G]

2. Permit Shield

Compliance with the conditions of this Part shall be deemed compliance with A.A.C. R18-2-730.D, R18-2-730.F, and R18-2-730.G.

[A.A.C. R18-2-325]

## **VIII. FUGITIVE DUST REQUIREMENTS**

### **A. Applicability**

This Section applies to any source of fugitive dust in the facility.

### **B. Particulate Matter and Opacity**

#### **1. Open Areas, Roadways & Streets, Storage Piles, and Material Handling**

##### **a. Emission Limitations/Standards**

- i. Opacity of emissions from any fugitive dust non-point source shall not be greater than 40 percent measured in accordance with the Arizona Testing Manual, Reference Method 9.

[A.A.C. R18-2-614]

- ii. The Permittee shall not cause, allow or permit visible emissions from any point source, in excess of 20 percent opacity.

[A.A.C. R18702.B]

- iii. The Permittee shall employ the following reasonable precautions to prevent excessive amounts of particulate matter from becoming airborne:

- (a) Keep dust and other types of air contaminants to a minimum in an open area where construction operations, repair operations, demolition activities, clearing operations, leveling operations, or any earth moving or excavating activities are taking place, by good modern practices such as using an approved dust suppressant or adhesive soil stabilizer, paving, covering, landscaping, continuous wetting, detouring, barring access, or other acceptable means;

[A.A.C. R18-2-604.A]

- (b) Keep dust to a minimum from driveways, parking areas, and vacant lots where motor vehicular activity occurs by using an approved dust suppressant, or adhesive soil stabilizer, or by paving, or by barring access to the property, or by other acceptable means;

[A.A.C. R18-2-604.B]

- (c) Keep dust and other particulates to a minimum by employing dust suppressants, temporary paving, detouring, wetting down or by other reasonable means when a roadway is repaired, constructed, or reconstructed;

[A.A.C. R18-2-605.A]

- (d) Take reasonable precautions, such as wetting, applying dust suppressants, or covering the load when transporting material likely to give rise to airborne dust; [A.A.C. R18-2-605.B]
- (e) Take reasonable precautions, such as the use of spray bars, wetting agents, dust suppressants, covering the load, and hoods when crushing, handling, or conveying material likely to give rise to airborne dust; [A.A.C. R18-2-606]
- (f) Take reasonable precautions such as chemical stabilization, wetting, or covering when organic or inorganic dust producing material is being stacked, piled, or otherwise stored; [A.A.C. R18-2-607.A]
- (g) Operate stacking and reclaiming machinery utilized at storage piles at all times with a minimum fall of material, or with the use of spray bars and wetting agents; [A.A.C. R18-2-607.B]
- (h) Any other method as proposed by the Permittee and approved by the Director. [A.A.C. R18-2-306.A.3.c]

b. Monitoring, Recordkeeping and Reporting Requirements

- i. The Permittee shall maintain records of the dates on which any of the activities listed in Conditions VIII.B.1.a.iii. above were performed and the control measures that were adopted. [A.A.C. R18-2-306.A.3.c]

ii. Opacity Monitoring Requirements

- (a) A certified Method 9 observer shall conduct a quarterly survey of visible emissions from the fugitive dust sources when the facility is in operation. The Permittee shall keep a record of the name of the observer, the date and location on which the observation was made, and the results of the observation.
- (b) If the observer sees a visible emission from a fugitive dust source that on an instantaneous basis appears to exceed applicable opacity standard, then the observer shall, if practicable, take a six-minute Method 9 observation of the visible emission.
  - (1) If the six-minute opacity of the visible emission is less than or equal to applicable opacity standard, the observer shall make a record of the following:
    - a) Location, date, and time of the observation; and
    - b) The result of the Method 9 observation.

(2). If the six-minute opacity of the visible emission exceeds applicable opacity standard, then the Permittee shall do the following:

- a) Adjust or repair the controls or equipment to reduce opacity to below the applicable standard; and
- b) Report it as an excess emission under Section XII.A of Attachment "A".

[A.A.C. R18-2-306.A.3.c]

c. Permit Shield

Compliance with the conditions of this Part shall be deemed compliance with A.A.C. R18-2-604.A, A.A.C. R18-2-604.B, A.A.C. R18-2-605, A.A.C. R18-2-606, A.A.C. R18-2-607, A.A.C. R18-2-612, A.A.C. R18-2-614 and A.A.C. R18-2-702.B.

[A.A.C. R18-2-325]

2. Open Burning

a. Emission Limitation/Standard

Except as provided in A.A.C. R18-2-602.C.1, C.2, C.3, and C.4, and except when permitted to do so by either ADEQ or the local officer delegated the authority for issuance of open burning permits, the Permittee shall not conduct open burning.

[A.A.C. R18-2-602]

b. Monitoring and Recordkeeping Requirement

Compliance with the requirements of Condition VIII.B.2.a above may be demonstrated by maintaining copies of all open burning permits on file.

[A.A.C. R18-2-306.A.3.c]

c. Permit Shield

Compliance with the conditions of this Part shall be deemed compliance with A.A.C. R18-2-602.

[A.A.C. R18-2-325]

## IX. MOBILE SOURCE REQUIREMENTS

### A. Applicability

The requirements of this Section are applicable to mobile sources which either move while emitting air contaminants or are frequently moved during the course of their utilization but are not classified as motor vehicles, agricultural vehicles, or agricultural equipment used in normal farm operations. Mobile sources shall not include portable sources as defined in A.A.C. R18-2-101.89.

[A.A.C. R18-2-801.A]

### B. Particulate Matter and Opacity

1. Emission Limitations/Standards

a. Off-Road Machinery

The Permittee shall not cause, allow, or permit to be emitted into the atmosphere from any off-road machinery, smoke for any period greater than ten consecutive seconds, the opacity of which exceeds 40 percent. Visible emissions when starting cold equipment shall be exempt from this requirement for the first ten minutes. Off-road machinery shall include trucks, graders, scrapers, rollers, and other construction and mining machinery not normally driven on a completed public roadway.

[A.A.C.R18-2-802.A and -802.B]

b. Roadway and Site Cleaning Machinery

i. The Permittee shall not cause, allow or permit to be emitted into the atmosphere from any roadway and site cleaning machinery smoke or dust for any period greater than ten consecutive seconds, the opacity of which exceeds 40 percent. Visible emissions when starting cold equipment shall be exempt from this requirement for the first ten minutes.

[A.A.C.R18-2-804.A]

ii. The Permittee shall take reasonable precautions, such as the use of dust suppressants, before the cleaning of a site, roadway, or alley. Earth or other material shall be removed from paved streets onto which earth or other material has been transported by trucking or earth moving equipment, erosion by water or by other means.

[A.A.C. R18-2-804.B]

c. Unless otherwise specified, no mobile source shall emit smoke or dust the opacity of which exceeds 40 percent.

[A.A.C.R18-2-801.B]

2. Recordkeeping Requirement

The Permittee shall keep a record of all emissions related maintenance activities performed on the Permittee's mobile sources stationed at the facility as per manufacturer's specifications.

[A.A.C.R18-2-306.A.5.a]

3. Permit Shield

Compliance with this Section shall be deemed compliance with A.A.C. R18-2-801, A.A.C. R18-2-802.A, A.A.C. R18-2-804.A and A.A.C. R18-2-804.B.

[A.A.C.R18-2-325]

**X. OTHER PERIODIC ACTIVITY REQUIREMENTS**

**A. Abrasive Blasting**

Particulate Matter and Opacity

1. Emission Limitations/Standards

a. The Permittee shall not cause or allow sandblasting or other abrasive blasting without minimizing dust emissions to the atmosphere through the use of good modern practices. Good modern practices include:

i. wet blasting;

- ii. effective enclosures with necessary dust collecting equipment; or
  - iii. any other method approved by the Director.
- [A.A.C. R18-2-726]

b. Opacity

The Permittee shall not cause, allow or permit visible emissions from sandblasting or other abrasive blasting operations in excess of 20 percent opacity as measured by EPA Reference Method 9. [A.A.C. R18-2-702.B.1]

2. Monitoring and Recordkeeping Requirement

Each time an abrasive blasting project is conducted, the Permittee shall log in ink or in an electronic format, a record of the following:

- a. The date the project was conducted;
- b. The duration of the project; and
- c. Type of control measures employed.

[A.A.C. R18-2-306.A.3.c]

3. Permit Shield

Compliance with this Part shall be deemed compliance with A.A.C. R18-2-726 and A.A.C. R18-2-702.B.1. [A.A.C. R18-2-325]

**B. Use of Paints**

1. Volatile Organic Compounds

a. Emission Limitations/Standards

While performing spray painting operations, the Permittee shall comply with the following requirements:

- i. The Permittee shall not conduct or cause to be conducted any spray painting operation without minimizing organic solvent emissions. Such operations, other than architectural coating and spot painting, shall be conducted in an enclosed area equipped with controls containing no less than 96 percent of the overspray.

[A.A.C. R18-2-727.A]

- ii. The Permittee or their designated contractor shall not either:

- (a) Employ, apply, evaporate, or dry any architectural coating containing photochemically reactive solvents for industrial or commercial purposes; or
- (b) Thin or dilute any architectural coating with a photochemically reactive solvent.

[A.A.C. R18-2-727.B]

- iii. For the purposes of Conditions X.B.1.a.ii. above a photochemically reactive solvent shall be any solvent with an



aggregate of more than 20 percent of its total volume composed of the chemical compounds classified in Conditions X.B.1.a.iii(a) through X.B.1.a.iii(c) below, or which exceeds any of the following percentage composition limitations, referred to the total volume of solvent:

- (a) A combination of the following types of compounds having an olefinic or cyclo-olefinic type of unsaturation-hydrocarbons, alcohols, aldehydes, esters, ethers, or ketones: 5 percent.
- (b) A combination of aromatic compounds with eight or more carbon atoms to the molecule except ethylbenzene: 8 percent.
- (c) A combination of ethylbenzene, ketones having branched hydrocarbon structures, trichloroethylene or toluene: 20 percent.

[A.A.C.R18-2-727.C]

## 2. Solvent Classification

Whenever any organic solvent or any constituent of an organic solvent may be classified from its chemical structure into more than one of the groups of organic compounds described in Conditions X.B.1.a.iii(a) through X.B.1.a.iii(c) above, it shall be considered to be a member of the group having the least allowable percent of the total volume of solvents.

[A.A.C.R18-2-727.D]

## 3. Monitoring and Recordkeeping Requirements

- a. Each time a spray painting project is conducted, the Permittee shall log in ink, or in an electronic format, a record of the following:
  - i. The date the project was conducted;
  - ii. The duration of the project;
  - iii. Type of control measures employed;
  - iv. Material Safety Data Sheets for all paints and solvents used in the project; and
  - v. The amount of paint consumed during the project.
  - vi. Architectural coating and spot painting projects shall be exempt from the recordkeeping requirements.

[A.A.C. R18-2-306.A.3.c]

## 4. Permit Shield

Compliance with this Part shall be deemed compliance with A.A.C.R18 2-727.

[A.A.C. R18-2-325]

## 5. Opacity

a. Emission Limitation/Standard

The Permittee shall not cause, allow or permit visible emissions from painting operations in excess of 20 percent opacity as measured by EPA Reference Method 9. [A.A.C. R18-2-702.B.1]

b. Permit Shield

Compliance with the conditions of this Part shall be deemed compliance with A.A.C.R18-2-702.B1. [A.A.C. R18-2-325]

**C. Demolition/Renovation - Hazardous Air Pollutants**

1. Emission Limitation/Standard

The Permittee shall comply with all of the requirements of 40 CFR 61 Subpart M (National Emissions Standards for Hazardous Air Pollutants - Asbestos). [A.A.C. R18-2-1101.A.8]

2. Monitoring and Recordkeeping Requirement

The Permittee shall keep all required records in a file. The required records shall include the “NESHAP Notification for Renovation and Demolition Activities” form and all supporting documents. [A.A.C. R18-2-306.A.3.c]

3. Permit Shield

Compliance with the conditions of this Part shall be deemed compliance with A.A.C. R18-2-1101.A.8. [A.A.C. R18-2-325]

**ATTACHMENT “C”: EQUIPMENT LIST**  
**Air Quality Control Permit No. 47943**  
**For**  
**General Motors Desert Proving Ground - Yuma**

<b>EQUIPMENT TYPE</b>	<b>Max. Rated Capacity</b>	<b>MAKE</b>	<b>MODEL</b>	<b>SERIAL NUMBER</b>	<b>DATE OF MFG.</b>	<b>Equipment ID Number</b>
Fuel Facility – Propane-fired Heater	0.149 MMBTU/hr	TMI	3200	08009001	NA	AH 27-1
Fuel Facility – Propane-fired Heater	0.106 MMBTU/hr	TMI	1500	08009002	NA	AH 27-2
Main Building – Mechanical Room Propane-fired Make-up Air Unit	0.500 MMBTU/hr	TMI	ADFH-300	Unknown	NA	AH 31-1
Main Building – Office Propane-fired Heater	0.335 MMBTU/hr	Reznor	16860	08009003	NA	AH 31-3
Main Building – Garage Propane-fired Heater	2.650 MMBTU/hr	TMI	35320	08009005	NA	AH 31-4
Main Building – Lab Propane-fired Heater	0.309 MMBTU/hr	TMI	19800	08009004	NA	AH 31-5
Warehouse Building - Propane-fired Heater	0.453 MMBTU/hr	TMI	18000	08009006	NA	AH 36-1
Main Building – Propane-fired Water Heater	270 MBTU/hr	PVI Industries	27 P 250A-MXS	Unknown	NA	WH 31-1
Fuel Facility - Propane-fired Water Heater	65 MBTU/hr	Bradford White	M-1-X504T6EN	Unknown	NA	WH 27-1
Emergency Generator Propane-fired	168 HP	Generac	QT100A	5043206	06/23/08	EM GEN
Emergency Fire Water Pump - Diesel-fired (Ultra-low Sulfur)	252 HP	Clarke	JW6H-UF38	Unknown	NA	EM WATER
Gasoline - UST	12,000 gal	Xerxes	8’ DIA DWT-11	A118260	NA	UST 1
Gasoline – UST	12,000 gal	Xerxes	8’ DIA DWT-11	A118257	NA	UST 2
Gasoline – UST	4,000 gal	Xerxes	6’ DIA DWT-11	A118266	NA	UST 3
Gasoline – UST	4,000 gal	Xerxes	6’ DIA DWT-11	A118265	NA	UST 4
Gasoline – UST	4,000 gal	Xerxes	6’ DIA DWT-11	A118191	NA	UST 5
Gasoline – UST	4,000 gal	Xerxes	6’ DIA DWT-11	A118194	NA	UST 6
Gasoline – UST	4,000 gal	Xerxes	6’ DIA DWT-11	A118199	NA	UST 7
Gasoline – UST	4,000 gal	Xerxes	6’ DIA DWT-11	A118190	NA	UST 8
Gasoline - UST	12,000 gal	Xerxes	8’ DIA DWT-11	A118262	NA	UST 10

<b>EQUIPMENT TYPE</b>	<b>MAX. CAPACITY</b>	<b>MAKE</b>	<b>MODEL</b>	<b>SERIAL NUMBER</b>	<b>DATE OF MFG.</b>	<b>Equipment ID Number</b>
Gasoline – Double-walled, Pressure, UST	12,000 gal	Brown Minneapolis	ASME STI-P3	260089	NA	UST 11
Gasoline – UST	25,000 gal	Xerxes	10' DIA DWT-11	A118258	NA	UST 12
Gasoline - UST	12,000 gal	Xerxes	8' DIA DWT-11	A118261	NA	UST 13
Gasoline – UST	12,000 gal	Xerxes	8' DIA DWT-11	A118256	NA	UST 14
Gasoline – UST	4,000 gal	Xerxes	6' DIA DWT-11	A118200	NA	UST 15
Gasoline – UST	4,000 gal	Xerxes	6' DIA DWT-11	A118202	NA	UST 16
Gasoline – UST	4,000 gal	Xerxes	6' DIA DWT-11	A118267	NA	UST 17
Gasoline – AST	1,000 gal	Unknown	Unknown	Unknown	NA	AST 1
Gasoline – AST	1,000 gal	Unknown	Unknown	Unknown	NA	AST 2
Gasoline – AST	350 gal	Unknown	Unknown	Unknown	NA	AST 3
Parts Washer (4) each	15 gal	Safety Kleen	Model 33	Unknown	NA	PW-1 to 4